



*Office of
Risk Management and Safety*

601 University Drive
San Marcos, Texas 78666-4615
office: 512.245.3616
fax: 512.245.8277

July 17, 2006

City of San Marcos
Mr. Ed Sprencel
Water Quality Supervisor
630 E. Hopkins
San Marcos, Texas 78666

Subject: Texas State University – San Marcos Compliance Report
Industrial Permit No. 8908-01, 8908-02, 8908-03, 9008-04, 9205-05, 9401-06,
9802-07, 0512-08, 0512-09


Dear Mr. Sprencel:

Please find enclosed the required compliance report for the above-referenced industrial permit outfalls. The data for this reporting period (January through June 2006) are summarized in the attached table and the laboratory reports are attached. The results show that Texas State University is in compliance with all parameters except mercury from sampling port 8908-02 (Freeman Aquatic Building located at Sessoms and Ed Green). In accordance with provision Part 3A of our permit, we notified the City within 24 hours of receiving the final laboratory report (fax dated July 10, 2006) and resampled this port (July 11, 2006) to confirm the exceedance. We have also initiated an investigation to try and identify the source. We will supply this additional information to you in a follow-up letter once the data is received.

The following certification is provided as required by the permit:

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information is to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Regards,


Mr. Terry Dowdy

cc: Enos Jones, Pat Fogarty, Jim Fox, Diana Trelles, Lisa Arceneaux

Table 1
 Summary of Wastewater Sample Data
 City of San Marcos Industrial Use Permit
 Texas State University - San Marcos

Sample I.D.	Permit Number	Date Collected	Arsenic (mg/L)	Cadmium (mg/L)	Chromium (mg/L)	Copper (mg/L)	Lead (mg/L)	Mercury (mg/L)	Nickel (mg/L)	Silver (mg/L)	Zinc (mg/L)	Cyanide (mg/L)
Pleasant/Sessoms	8908-01	6/21/2006	<0.02	<0.02	<0.1	0.1	<0.02	0.00026	<0.02	<0.1	0.2	<0.02
Ed Green/Sessoms	8908-02	6/21/2006	<0.02	<0.02	<0.1	<0.1	<0.02	0.0156 (a)	<0.02	<0.1	<0.1	0.071
Ed Green/Sessoms resample	8908-02	7/11/2006	-	-	-	-	-	0.00025 (a)	-	-	-	-
Comanche	8908-03	6/21/2006	<0.02	<0.02	<0.1	<0.1	<0.02	<0.0002	<0.02	<0.1	<0.1	<0.02
Facilities/Plumbing Shop	9008-04	6/21/2006	<0.02	<0.02	<0.1	0.1	<0.02	0.00056	<0.02	<0.1	0.4	<0.02
Front of Physical Plant	9205-05	6/21/2006	<0.02	<0.02	<0.1	<0.1	<0.02	0.0004	<0.02	<0.1	<0.1	<0.02
Moon Street	9401-06	6/20/2006	<0.02	<0.02	<0.1	0.2	<0.02	<0.0002	<0.02	0.1	0.2	<0.02
CoGen by Gate	9802-07	6/20/2006	<0.02	<0.02	<0.1	<0.1	<0.02	<0.0002	<0.02	<0.1	<0.1	<0.02
Lindsey Street	0512-08	6/20/2006	<0.02	<0.02	<0.1	0.3	<0.02	<0.0002	<0.02	<0.1	0.2	<0.02
Strahan	0512-09	6/20/2006	<0.02	<0.02	<0.1	1.2	0.066	0.00021	0.022	<0.1	0.7	<0.02
Permit Limit			0.18	0.36	1.62	4.57	0.65	0.01	5.57	0.306	1.6	0.74
			pH	cBOD (mg/L)	COD (mg/L)	TSS (mg/L)	Total NH3 as N (mg/L)	Phosphorous (mg/L)	Aluminum (mg/L)	Molybdenum (mg/L)	Selenium (mg/L)	
Pleasant/Sessoms	8908-01	6/21/2006	8.33	78	325	217	20	6.85	0.165	0.0502	<0.02	
Ed Green/Sessoms	8908-02	6/21/2006	7.78	54	89	267	1.1	1.2	0.267	0.674	<0.02	
Comanche	8908-03	6/21/2006	8.26	28	157	160	11	4.23	<0.08	<0.04	<0.02	
Facilities/Plumbing Shop	9008-04	6/21/2006	8.14	258	790	261	17.2	10.9	0.106	<0.04	<0.02	
Front of Physical Plant	9205-05	6/21/2006	8.73	71	313	226	47.1	12.35	0.208	<0.04	<0.02	
Moon Street	9401-06	6/20/2006	7.99	151	421	444	22.7	8.63	0.582	0.0686	<0.02	
CoGen by Gate	9802-07	6/20/2006	7.93	248	281	183	18.2	8.43	<0.08	0.559	<0.02	
Lindsey Street	0512-08	6/20/2006	7.47	73	191	102	5.6	5.23	0.17	<0.04	<0.02	
Strahan	0512-09	6/20/2006	8.36	139	561	1150	41.6	16.18	3.4	<0.04	<0.02	
Permit Limit			>6.00	NS	NS	NS	NS	NS	NS	2.44	0.17	

Notes:
 NS = not specified in permit
 (a) Initial sample collected 6/20/06, mercury concentration 0.0156 mg/L. Resample collected 7-11-06 did not confirm exceedance.

January 2006 through June 2006 flow to sewer:

January-06	14,128,826
February-06	18,300,888
March-06	14,252,731
April-06	17,893,165
May-06	12,506,057
June-06	11,306,016
Total	88,387,683

Attachment A

Laboratory Reports
January – June 2006 Sampling Period

(data on file at RMSO)