



**TEXAS  
STATE**  
UNIVERSITY  
SAN MARCOS

January 12, 2006

---

City of San Marcos  
Mr. Alfonso Carmona  
Water and Wastewater Plant Manager  
720 River Road  
San Marcos, Texas 78666

Subject: Texas State University – San Marcos Compliance Report


---

Mr. Carmona,

The required compliance report is attached for Industrial User Permit No. 8908-01, 8908-02, 8908-03, 9008-04, 9205-05, 9401-06 and 9802-07. Results show Texas State University – San Marcos to be in compliance with limits as defined in our Wastewater Discharge Permit.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information is to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Regards,

  
Mr. Terry Dowdy

cc: Enos Jones, Pat Fogarty, Jim Fox, Diana Trelles, Lisa Arceneaux

Table 1  
 Summary of Wastewater Sample Data  
 City of San Marcos Industrial Use Permit  
 Texas State University - San Marcos

Sample I.D.	Permit Number	Date Collected	Arsenic (mg/L)	Cadmium (mg/L)	Chromium (mg/L)	Copper (mg/L)	Lead (mg/L)	Mercury (mg/L)	Nickel (mg/L)	Silver (mg/L)	Zinc (mg/L)	Cyanide (mg/L)
			pH	cBOD (mg/L)	COD (mg/L)	TSS (mg/L)	Total NH3 as N (mg/L)	Phosphorous (mg/L)	Aluminum (mg/L)	Molybdenum (mg/L)	Selenium (mg/L)	
Pleasant/Sessoms	8908-01	12/15/2005	<0.02	<0.02	0.1	0.1	<0.02	<0.0002	<0.1	<0.1	<0.1	<0.02
Ed Green/Sessoms	8908-02	12/15/2005	<0.02	<0.02	0.1	<0.1	<0.02	0.00028	<0.1	<0.1	<0.1	<0.02
Commanche	8908-03	12/16/2005	<0.02	<0.02	0.1	<0.1	<0.02	<0.0002	<0.1	<0.1	<0.1	<0.02
Front Sessoms	9008-04	12/15/2005	<0.02	<0.02	0.1	<0.1	<0.02	0.00079	<0.1	<0.1	<0.1	<0.02
Physical Plant Back	9205-05	12/15/2005	<0.02	<0.02	0.1	<0.1	<0.02	<0.0002	<0.1	<0.1	0.2	<0.02
Moon Street	9401-06	12/16/2005	<0.02	<0.02	0.1	0.5	<0.02	<0.0002	<0.1	<0.1	<0.1	<0.02
CoGen by Gate	9802-07	12/16/2005	<0.02	<0.02	0.1	0.3	<0.02	<0.0002	<0.1	<0.1	<0.1	<0.02
<i>Permit Limit</i>			0.18	0.36	1.62	4.57	0.65	0.01	5.57	0.306	1.6	0.74
Pleasant/Sessoms	8908-01	12/15/2005	7.94	122	274	114	24.9	7.7	0.125	0.774	<0.02	<0.02
Ed Green/Sessoms	8908-02	12/15/2005	7.91	15	<50	13	0.8	0.9	<0.08	<0.04	<0.02	<0.02
Commanche	8908-03	12/16/2005	8.00	62	153	82	5.3	2.73	<0.08	<0.04	<0.02	<0.02
Front Sessoms	9008-04	12/15/2005	8.46	21	364	281	49	16.68	0.3	<0.04	<0.02	<0.02
Physical Plant Back	9205-05	12/15/2005	8.09	17	133	116	14.7	3.58	0.153	<0.04	<0.02	<0.02
Moon Street	9401-06	12/16/2005	7.73	300	595	944	17.7	11.2	0.207	0.0919	<0.02	<0.02
CoGen by Gate	9802-07	12/16/2005	6.01	69	372	115	15.5	11.08	0.284	0.0858	<0.02	<0.02
<i>Permit Limit</i>			>6.00	NS	NS	NS	NS	NS	NS	2.44	0.17	

Notes:  
 NS = not specified in permit

**July 2005 through December 2005 Flows to Sewer**

July-05	12,007,658
August-05	14,610,637
September-05	19,494,259
October-05	18,191,426
November-05	16,632,251
December-05	13,523,667
<b>Total</b>	<b>94,459,898</b>

## **Attachment A**

Laboratory Reports  
July – December 2005 Sampling Period

(data on file at RMSO)